



Intertek Testing Services Shanghai
Building No.86, 1198 Qinzhou Road (North),
Caohejing Development Zone,
Shanghai 200233, China
Tel:86 21 6127 8200 Fax:86 21 6495 6263

Test Verification of Conformity

On the basis of the tests undertaken, the sample(s) of the below product have been found to comply with the requirements of the referenced specifications at the time the tests were carried out.

Applicant Name & Address : Afore New Energy Technology(Shanghai)Co., Ltd.
1st &2nd Floor, B Building, Business Building, No.2 Building,
No.1588, Lianhang road, Minhang District, Shanghai, China
201112

Manufacturing site Name & Address : Same as applicant

Product(s) Tested : PV Grid interconnected inverter

Ratings and principal characteristics : See Annex

Model(s) : See Annex

Brand name : Afore

Relevant Standard(s) / Specification(s) : IEC 62116 :2014+ IEC 61727:2004+ IEC 61683:1999
IEC 60068-2-1: 2007 Test A: Cold
IEC 60068-2-2: 2007 Test B: Dry heat
IEC 60068-2-14:2009 Test N: Change of temperature
IEC60068-2-30: 2005 Test Db: Damp heat, cyclic
12+12h cycle)


Verification Issuing Office Name & Address : Intertek Testing Services Shanghai
Building No.86, 1198 Qinzhou Road (North), Shanghai 200233,
China

Verification Number : 170301701SHA-V1

Report Number(s) : 170301701SHA-001/002/003/004

NOTE 1: This verification is part of the full test report(s) and should be read in conjunction with it.

This Verification is for the exclusive use of Intertek's Client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Verification. Only the Client is authorized to copy or distribute this Verification. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test results referenced from this Verification are relevant only to the sample tested. This Verification by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.



Signature
Name: Jonny Jing
Position: Manager
Date: 2017-06-08

Annex to Test Verification of Conformity

This is an Annex to Test Verification of Conformity with Verification/Report Number(s):
 170301701SHA-V1/ 170301701SHA-001/002/003/004. The issuing office is Intertek Testing Services Shanghai
 (Address: Building No.86, 1198 Qinzhou Road (North), Caohejing Development Zone, Shanghai 200233, China).


Rating table				
Model	BNT015KTL	BNT017KTL	BNT020KTL	BNT025KTL
Input:				
Vmax PV (Vdc)	1000	1000	1000	1000
Isc PV (absolute Max.) (A)	24*2	26*2	27.5*2	37.5*2
Number MPP trackers	2	2	2	2
Number input strings	2/2	2/2	2/2	3/3
Max. PV input current(A)	19*2	21*2	22*2	30*2
MPPT voltage range (Vdc)	300-800	300-800	300-800	300-800
Vdc range @ full power (Vdc)	500-800	500-800	500-800	500-800
Output				
Normal Voltage(V)	<input type="checkbox"/> 1/N/PE 230Vac <input checked="" type="checkbox"/> 3/N/PE 230/400Vac			
Frequency(Hz)	<input checked="" type="checkbox"/> 50 Hz <input type="checkbox"/> 60Hz			
Current (normal) (A)	22	25	29	36
Current (Max. continuous) (A)	27	30	32	40
Power rating (W)	15000	17000	20000	25000
Power Rating(VA)	15000	17000	20000	25000
Power factor /rated	-0.95~+0.95	-0.95~+0.95	-0.95~+0.95	-0.95~+0.95
others				
Protective class	Class I			
Ingress protection (IP)	IP 65			
Temperature(°C)	-20°C to +55°C (up 45°C derating)			
Inverter Isolation	<input checked="" type="checkbox"/> Non-isolated <input type="checkbox"/> High frequency isolated			
Weight (kg)	40 (15,17,20kW) 42 (25, 30kW)			

Annex to Test Verification of Conformity

Rating table			
Model	BNT030KTL		
Input:			
Vmax PV (Vdc)	1000		
Isc PV (absolute Max.) (A)	41/41		
Number MPP trackers	2		
Number input strings	3/3		
Max. PV input current(A)	33/33		
MPPT voltage range (Vdc)	300-800		
Vdc range @ full power (Vdc)	500-800		
Output			
Normal Voltage(V)	<input type="checkbox"/> 1/N/PE 230Vac <input checked="" type="checkbox"/> 3/N/PE 230/400Vac		
Frequency(Hz)	<input checked="" type="checkbox"/> 50 Hz <input type="checkbox"/> 60Hz		
Current (normal) (A)	43		
Current (Max. continuous) (A)	45		
Power rating (W)	30000W		
Power Rating(VA)	30000VA		
Power factor /rated	-0.95~+0.95		
others			
Protective class	Class I		
Ingress protection (IP)	IP 65		
Temperature(°C)	-20°C to +55°C (up 45°C derating)		
Inverter Isolation	<input checked="" type="checkbox"/> Non-isolated <input type="checkbox"/> High frequency isolated		
Weight (kg)	40kg(15,17,20kW) 42kg(25, 30kW)		

NOTE: This annex is part of the Test Verification of Conformity and should be read in conjunction with it.

This Verification is for the exclusive use of Intertek's Client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Verification. Only the Client is authorized to copy or distribute this Verification. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test results referenced from this Verification are relevant only to the sample tested. This Verification by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.


 Signature
 Name: Jonny Jing
 Position: Manager
 Date: 2017-06-08