

# Test Verification of Conformity

Verification Number: 2412B0916SHA-V1

On the basis of the tests undertaken, the sample<s> of the below product has been tested by an accredited 3rd party laboratory in accordance to the referenced specification<s>/standard<s> at the time the tests were carried out. This verification is part of the full test report<s> and should be read in conjunction with it <them>.

This document can be used in support of a claim in meeting relevant < EU Low Voltage Directive (LVD) (2014/35/EU)>legislation and mandatory Conformity Marking. And in accordance with EU / UK law, the claim is the sole obligation of the Manufacturer/ Importer.

Applicant Name & Address:	Afore New Energy Technology (Shanghai) Co., Ltd. Building 7, No.333 Wanfang Rd, Minhang District, Shanghai, China. 201112
Product Description:	Hybrid Inverter
Ratings & Principle Characteristics:	See Appendix(Specifications table)
Models/Type References:	AF*-SLP-0 (*=7K, 8K, 9K, 10K, 11K, 12K) AF*-SLP (*=7K, 8K, 9K, 10K, 11K, 12K)
Brand Names:	Afore
Specification<s>/Standards:	IEC 61683:1999
Verification Issuing Office Name & Address:	Intertek Testing Services (Shanghai FTZ) Co., Ltd. Building No.86, 1198 Qinzhou Road (North), Shanghai 200233, China
Date of Tests:	2024-12-11 to 2024-12-31
Test Report Number(s):	2412B0916SHA-001
Additional information in Appendix.	

Signature



Name: Max Jin

Position: General Manager

Date: 2024-12-31

This Verification is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Verification. Only the Client is authorized to permit copying or distribution of this Verification. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test/inspection results referenced in this Verification are relevant only to the sample tested/inspected. This Verification by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.

## APPENDIX: Test Verification of Conformity

This is an Appendix to Test Verification of Conformity Number: 2412B0916SHA-V1

Manufacture Name & Address: Same as applicant

Specifications table						
Model	AF7K-SLP	AF8K-SLP	AF9K-SLP	AF10K-SLP	AF11K-SLP	AF12K-SLP
<b>PV input</b>						
P <sub>pv</sub> Max(kW)	10.5	12	13.5	15	16.5	18
V <sub>max</sub> PV (Vdc) (absolute Max.)	550	550	550	550	550	550
I <sub>sc</sub> PV (absolute Max.) (A)	26 x 3	26 x 3	26 x 3	26 x 3	26 x 3	26 x 3
Number MPP trackers	3	3	3	3	3	3
Number input strings	1/1/2	1/1/2	1/1/2	1/1/2	1/1/2	1/1/2
Max. PV input current / strings (A)	18.5 x 3	18.5 x 3	18.5 x 3	18.5 x 3	18.5 x 3	18.5 x 3
MPPT voltage range (Vdc)	80-500	80-500	80-500	80-500	80-500	80-500
Vdc range @ full power (Vdc)	140-500	150-500	170-500	190-500	210-500	230-500
<b>Battery (charge/discharge)</b>						
Battery type	Li-ion/Lead-acid etc.					
Battery Normal Voltage (Range) (Vdc)	51.2V (40-60V)					
Max charge/discharge Current(A)	200	200	240	240	240	240
Max charge/discharge Power(kW)	7	8	9	10	11	12
<b>AC Grid (input and output)</b>						
Normal AC Voltage (VAC)	L/N/PE, 230Vac					
Frequency (Hz)	50					
Normal AC Current (A)	30.5	34.8	39.2	43.5	47.9	52.2
Max. cont. input/output current (A)	32	37	41	46	50	55
Rated Power(kW)	7	8	9	10	11	12
Rated Apparent Power (kVA)	7	8	9	10	11	12
Max. cont. Power (kW)	7	8	9	10	11	12
Max. cont. Apparent Power (kVA)	7	8	9	10	11	12
Power factor (adjustable)	1.0(-0.8~ +0.8)					
<b>AC Load output (stand alone)</b>						
Normal Voltage (VAC)	L/N/PE, 230Vac					
Frequency (Hz)	50					
Nominal Current(A)	30.5	34.8	39.2	43.5	47.9	52.2
Max. cont. current (A)	32	37	41	46	50	55
Max. cont. Power (kW)	7	8	9	10	11	12
Max. cont. Apparent Power (kVA)	7	8	9	10	11	12
Power factor	1.0					
<b>Others</b>						
Ingress protection (IP)	IP66					
Protective class	Class I					
Temperature (°C)	-25°C to +60°C (Derating 45°C)					
Inverter Isolation	Non-isolated (PV - AC - BAT)					
Overvoltage category	OVC III (AC Main), OVC II (DC)					
Firmware	1.02					

This Verification is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Verification. Only the Client is authorized to permit copying or distribution of this Verification. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test/inspection results referenced in this Verification are relevant only to the sample tested/inspected. This Verification by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.

## APPENDIX: Test Verification of Conformity

This is an Appendix to Test Verification of Conformity Number: 2412B0916SHA-V1

Specifications table						
Model	AF7K-SLP-0	AF8K-SLP-0	AF9K-SLP-0	AF10K-SLP-0	AF11K-SLP-0	AF12K-SLP-0
<b>Battery (charge/discharge)</b>						
Battery type	Li-ion/Lead-acid etc.					
Battery Normal Voltage (Range) (Vdc)	51.2V (40-60V)					
Max charge/discharge Current(A)	200	200	240	240	240	240
Max charge/discharge Power(kW)	7 / 7.7	8 / 8.8	9 / 9.9	10 / 11	11 / 12.1	12 / 13.2
<b>AC Grid (input and output)</b>						
Normal AC Voltage (VAC)	L/N/PE, 230Vac					
Frequency (Hz)	50					
Normal AC Current (A)	30.5	34.8	39.2	43.5	47.9	52.2
Max. cont. input/output current (A)	32	37	41	46	50	55
Rated Power(kW)	7	8	9	10	11	12
Rated Apparent Power (kVA)	7	8	9	10	11	12
Max. cont. Power (kW)	7	8	9	10	11	12
Max. cont. Apparent Power (kVA)	7	8	9	10	11	12
Power factor (adjustable)	1.0(-0.8~ +0.8)					
<b>AC Load output (stand alone)</b>						
Normal Voltage (VAC)	L/N/PE, 230Vac					
Frequency (Hz)	50					
Nominal Current(A)	30.5	34.8	39.2	43.5	47.9	52.2
Max. cont. current (A)	32	37	41	46	50	55
Max. cont. Power (kW)	7	8	9	10	11	12
Max. cont. Apparent Power (kVA)	7	8	9	10	11	12
Power factor	1.0					
<b>Others</b>						
Ingress protection (IP)	IP66					
Protective class	Class I					
Temperature (°C)	-25°C to +60°C (Derating 45°C)					
Inverter Isolation	Non-isolated (AC - BAT)					
Overvoltage category	OVC III (AC Main), OVC II (DC)					
Firmware	1.02					

Signature



**Name: Max Jin**

**Position: General Manager**

**Date: 2024-12-31**

This Verification is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Verification. Only the Client is authorized to permit copying or distribution of this Verification. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test/inspection results referenced in this Verification are relevant only to the sample tested/inspected. This Verification by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.